
DATE:	January 30, 2009	Material Testing • Non-Destructive Testing Product Evaluation • Construction Materials
TO:	Mr. Bob Cruso Nycon, Inc. 101 Cross Street Westerly, RI 02891	662 Cromwell Avenue St. Paul, MN 55114 USA Telephone : (651) 645-3601 Telefax : (651) 659-7348 Website : www.storktct.com
PROJECT:	PERFORMANCE EVALUATION SYNTHETIC FIBERS	PROJECT NO.: 309006.1L2 PAGE: 1 of 1

TESTING OF CONCRETE WITH SYNTHETIC FIBERS**INTRODUCTION:**

This report presents the results of our laboratory testing work conducted on samples of concrete containing NyconLC Fiber (1.0 lb/yd³ dosage rate). Our work was requested and authorized by Mr. Bob Cruso of Nycon on January 14 and 16, 2009, respectively. The scope of our testing work was as follows:


1. Perform laboratory batching of concrete with and without fibers according to Section 4.0 of ICC-ES Acceptance Criteria for Concrete with Synthetic Fibers (AC32) for
A. Plastic Shrinkage Cracking
2. Prepare a written report stating the results of the areas tested in accordance with AC32.

CONCLUSIONS:

Based on the test results, the NyconLC Fibers, at a dosage rate of 0.59 kg/m³ (1.0 lbs/yd³), does meet the ICC-ES Acceptance Criteria for Concrete with Synthetic Fibers (AC32) Section 4.5.

REMARKS:


The samples were discarded at the completion of testing. If you have any questions concerning this report, or if we may be of further assistance, please contact me at (651) 659-7399.

STORK TWIN CITY TESTING CORPORATION

Thaddeaus Harnois, P.E.

Staff Engineer

F:\BMC\2009\CME\Construction\309006\NyconLC Shrinkage Letter 2.doc



Thomas A. Kolden, P.E.

Manager of Specialty Testing

This agreement shall be governed exclusively by the general terms and conditions of sale and performance of testing services by Stork Twin City Testing, Inc. a North Carolina business corporation ("TCT") dd. 05/01/2001. In no event shall Stork Twin City Testing, Inc. be liable for any consequential, special or indirect loss or any damages above the cost of the work. Payment is due within 30 days of invoice.